

# Lindab Premium / Premax

Active chilled beam

Installation instructions



# Installation instruction

# Premium/Premax

## 1. Content and symbols

<b>1. Content and symbols .....</b>	<b>2</b>
1.1 Content .....	2
1.2 Symbols .....	3
<b>2. Control of delivery .....</b>	<b>3</b>
2.1 Before starting .....	3
2.2 Safe operation .....	3
2.3 Receipt of goods .....	3
2.4 Unloading of goods .....	3
2.5 Handling / Carrying .....	3
2.6 Tools .....	4
2.7 Installation .....	4
2.8 Where to find additional instructions or technical documentation .....	4
2.9 Cleaning after assembly/before commissioning .....	4
2.10 Packing, unpacking guideline .....	5
2.11 Product labelling .....	6
2.12 Order code .....	7
2.13 Order code examples .....	7
2.14 Label .....	7
2.15 Contents of order .....	8
2.16 Plus features .....	8
2.16.1 Inlet faceplates .....	8
2.16.2 Outlet front grilles .....	8
2.16.3 Integrated valves .....	8
2.16.4 Integrated Actuators .....	8
2.16.5 Integrated Regula components .....	8
2.16.6 Airguides .....	8
2.16.7 Heating .....	8
2.17 Accessories .....	8
<b>3. Product specification .....</b>	<b>9</b>
3.1 Product description .....	9
3.2 Dimensions .....	9
3.3 Premium / Premax .....	10
3.4 Material data .....	10
3.5 Environmental Declarations .....	10
3.6 Pressure class .....	10
3.7 Water quality .....	10
3.8 Air quality .....	11
3.9 Capacity test .....	11
<b>4. Connections .....</b>	<b>12</b>
4.1 Water connections .....	12
4.1.1 Before installation .....	12
4.1.2 Push on fitting .....	13
4.1.3 Compression fitting .....	13
4.1.4 Flexible hoses .....	13
4.1.5 Possible connections water cooling (2-pipe, standard) .....	14
4.1.6 Possible connections water cooling and heating (4-pipe, plus feature) .....	15
4.2 Air connections .....	16
4.2.1 Air connection installation .....	16
4.2.2 Possible connections supply air .....	16
4.2.3 Possible connections extract air .....	16
4.3 Possible combination of connections .....	16
4.4 Electrical connections .....	17
4.4.1 Regula components on the beam .....	17

4.4.2 Example 1: Wiring scheme with Regula Connect multi .....	18
4.4.3 Example 2: Wiring scheme with Regula Connect basic .....	18
4.4.4 Regula Connect on the beam .....	19
4.4.5 Regula Secura on the beam .....	19
4.4.6 Valves and Actuators on the beam .....	19
4.4.7 Regula Combi on/with the beam .....	19
4.4.8 Actuators .....	19
<b>5. Installation of product .....</b>	<b>20</b>
5.1 Handling of product .....	20
5.2 Adaption to ceiling systems .....	20
5.2.1 Ceiling systems .....	20
5.3 General installation principles .....	21
5.3.1 Recessed in suspended T-bar ceiling .....	21
5.3.2 Exposed, sealed to the ceiling .....	21
5.3.3 Exposed, free hanging .....	21
5.3.4 Free hanging above perforated or eggcrate ceiling .....	21
5.3.5 Recessed in suspended (permanent) ceiling .....	21
5.3.6 Recessed in suspended (permanent) ceiling without cover flanges .....	21
5.4 Preparation for installation on the product .....	22
5.5 Basics steps of installing the product .....	24
<b>6. Adjustment and commissioning .....</b>	<b>25</b>
6.1 Airflow and pressure .....	25
6.1.1 Jet cone adjustment pins .....	25
6.1.2 Finding values for JetCone pins .....	27
6.1.3 Adjusting air flow and pressure with JetCone pins .....	27
6.2 Adjustment of air distribution profile .....	29
6.3 Measuring air pressure and calculating the air flow .....	30
6.3.1 Measuring static nozzle pressure and air pressure .....	30
6.3.2 Calculating the actual air flow .....	31
6.3.3 Changing the actual air flow .....	31
6.3.4 Changing the air distribution profile .....	31
6.3.5 Premium / Premax pressure / airflow diagrams .....	31
6.4 Water flow rate .....	32
6.4.1 Pre-setting of valves .....	32
6.4.2 Balancing strategy .....	32
<b>7. Maintenance .....</b>	<b>33</b>
7.1 Remove the outlet front grille .....	33
7.2 Open inlet faceplate .....	33
7.3 Opening inspection hatch .....	33
7.4 Lower battery .....	33
<b>8. Accessories .....</b>	<b>34</b>

# Installation instruction

# Premium/Premax

## 1.2 Symbols




Hot water

Heavy Load - 2 man job -  
It is recommended to use  
a "lift" for mounting.

Cold water



Hand-pull



Vacuum cleaner



Dust cleaner

## 2. Control of delivery

### 2.1 Before starting

Read through the entire installation instruction before commencing installation in order to determine which parts that needs to be performed and in what order to be done.

Lindab is a supplier of complete water products, but we offer also a wide range of accessories which suit perfectly to our water products simplifying your installation work, e.g. different type of hangers, Tektite-couplings, closing valves, thermostatic valves and actuators, flexible hoses, customized regulation components, customized cabeling and more. See also the separate document "Accessories."

Lindab will also provide you with a full ventilation system, with a wide range of Lindab Safe components. See also "Air Duct Systems."

### 2.2 Safe operation

Beware of sharp edges, especially of the coils. Always wear thin gloves and protective clothing.

All existing safety regulations must be observed when working with Lindab water products. Check the weights of the beams or the panels with the installation instruction before carrying.

### 2.3 Receipt of goods

Start by checking that the delivery is complete according to the order and that everything listed on the consignment note has been delivered. Then carry out a review of the products and make sure that nothing was damaged during transportation. If you discover damage that has occurred during delivery, it must be notified immediately.

Lindab is not responsible for costs associated with the replacement of products, that have been installed in any way other than shown in these installation instructions.

## 2.4 Unloading of goods

The beams and panels are normally delivered packed on wooden pallets. Lift the pallets carefully with a fork lift and place them on a dry and plain surface/ground. If the beams are delivered in single boxes, wooden blocks should be placed on the ground at one-metre intervals (or a pallet), before the boxes are been placed to store. Lindabs water products must be stored on a plane surface in a dry and well ventilated place, preferably indoors. If they have to be stored outdoors, protect them with a waterproof cover and store them protected from rain beneath a roof or other until they are fitted.

### 2.5 Handling / Carrying

The beam or panel must be handled with care, ensuring that it will not be scratched or bended during transportation, preparation and installation.

Always carry the beams or panels piecewise into the building. Keep the product in the package as long as you can.

Never use piping connections or edges to lift them, neither when you unpack them nor when you carry them towards the construction site.



Do not place the product directly on the floor. Use the protective corners from package or other clean means from package to place the product before installation.

Be careful if you must carry a long panel horizontally; if the panels are bended lengthwise, the profiles may be deformed and the piping could loosen from the panel. When opening the box with a knife, be careful not to damage the product.


Each beam is equipped with protective film to avoid any damage during transportation and handling on building site. The film needs to be removed before commissioning the products.

# Installation instruction

# Premium/Premax

## 2.6 Tools

To install the beam, panel or facade unit, the following tools are required.



## 2.7 Installation

It is important to use the correct hangers and the recommended amount for all installation principles. Different possible installation principles are shown in the installation instruction and hangers from Lindab should be used to ensure, that they are intended for the purpose and are safe to use.

Lindab's water products can be ordered, to be adapted to a wide range of different ceiling systems, please check installation instruction to ensure best adaptation.

The Lindab water products should always be installed separately hanged up from the recessed ceiling. The weight of the product should not be covered by the ceiling system.

Use plastic folio or other to protect the product during on site construction continually to keep the products in best condition and avoid any scratches.

## 2.8 Where to find additional instructions or technical documentation

In the following chapters we will refer to additional technical documents or/and instructions by a certain keyword written as a link.

If so you will easily find it with our Lindab Quick Selection Tool: [www.lindQST.com](http://www.lindQST.com)

1. Visit [www.lindQST.com](http://www.lindQST.com)
2. Select "documentation finder"
3. Select keyword (product name)
4. Follow the link
5. Find your document under "Related documents"


## 2.9 Cleaning after assembly/ before commissioning

Please remember to remove plastic folio and other protection material before commissioning and clean the product before hand over.

# Installation instruction

## Premium/Premax


## 2.10 Packing, unpacking guideline



# Installation instruction

# Premium/Premax


## 2.11 Product labelling



# Installation instruction


# Premium/Premax

## 2.12 Order code



\* As a plus feature the Premium/Premax Y-60 and Z-60 models can be ordered as well. See 3.2 for more details.

## 2.13 Order code examples



## 2.14 Label

On the label you will find:

- Order : Order identification number.
- Batch : Batch identification number.
- Product : Product configuration.
- Goods mark : Marking noted on order.
- Product ID : Product number.
- Sign : To be signed when checked and commissioned on site.



# Installation instruction

# Premium/Premax

## 2.15 Contents of order

### Standard package/order contains:

- Beam
- Plus features (pre-installed in factory)
- 4 pc/beam of copper insets (separate in smaller box)
- Accessories (separate in smaller box)

## 2.16 Plus features

The plus features offer a wide range of combinations with pre-installed accessories integrated into the product on production site. This reduces the installation time on site.

### 2.16.1 Inlet faceplates / 2.16.2 Outlet front grilles

Not relevant for Premium/Premax

## 2.16.3 Integrated valves



LinFlow-S, straight valve



LinFlow-A, angled valve

See [LinFlow-A](#) and [LinFlow-S](#) for details.

As the product is compact, the valves will come prepared to push-on to the water outlet pipe (enclosed valves). Ready equipped with adapter ring, actuator, cabled to the Regula connect card (if ordered accordingly) and positioned with an adhesive tape near to the piping.

## 2.16.4 Thermoelectric actuators



A-40405  
Actuator



APR-40405  
Actuator




VA 64  
Adapter ring

The actuators can be pre-installed on the integrated/enclosed valves and connected to the integrated Regula connect card /Regula Secura (plus feature). Go to [Actuators](#) for details. See also [Adapter ring](#).

## 2.16.5 Integrated Regula components




Regula Combi



Condensation sensor and Regula Secura



Regula Multi connect card



Go to [Regula](#) for details.


## 2.16.6 Airguides

The Lindab AirGuide system offers readjustable air spread pattern control. The AirGuide deflectors integrated in the Premium/Premax faceplate have 32 different settings. For details see 6.2.



## 2.16.7 Heating

Premium/Premax is in the standard version always equipped with a cooling in/out "2-pipe connection." The beams can be equipped with an additional heating circuit, providing a heating function as well as cooling.



## 2.17 Accessories

Here are some general accessories. For full range and order numbers, see separate [Accessories](#) document. The components under 2.16.3 to 2.16.5 are also available as accessories. Go to "8. Accessories" in this document to find accessories order numbers.

### Threaded rod kit



M8 x4 per beam.

Go to 5.4 "Preparation for installation on the product" for more details. Order no: See [Accessories](#).

### Flexible hoses



Order no: 680080 (0.4m push on, 12 and 12 mm).  
See [Accessories](#)

### Transformer



Order no:  
See [Transformers](#)

### Tectite fittings



Order no: 647690, 884050 and 642623 (12 mm).  
see [Accessories](#)


# Installation instruction Premium/Premax

## 3. Product specification


### 3.1 Product description

The Premium/Premax air beams are standardly prepared for ventilation and cooling (2-pipe connection). They are available in ceiling system integrateable I-60, I-62 and X-60 models. As a plus feature also integrateable Y-60 and Z-60 models are available.


### 3.2 Dimensions




Premium/Premax I-60 / I-62



Premium/Premax X-60



Premium/Premax Y-60 / Z-60  
Plus feature models



PREMAX	L* (mm)	A (mm)	B (mm)	kg / m	Ceiling type
I-60	1200, 1800, 2400, 3000, 3600	1192, 1792, 2392, 2992, 3592	592	18	01, 02
I-62	1200, 1800, 2400, 3000, 3600	1242, 1867, 2492, 3117, 3742	617		21, 22
X-60	1200, 1800, 2400, 3000, 3600	1199, 1799, 2399, 2999, 3599	599		03, 04, 05, 06, 07, 08, 14

Premax plus feature models

PREMAX	L* (mm)	A (mm)	B (mm)	kg / m	Ceiling type
Y-60	1200, 1800, 2400, 3000, 3600	1174, 1774, 2374, 2974, 3574	575	18	09, 11
Z-60	1200, 1800, 2400, 3000, 3600	1184, 1784, 2384, 2984, 3584	584		10

L\* = Nominal length ( Order length ).

PREMUM	L* (mm)	A (mm)	B (mm)	kg / m	Ceiling type
I-60	1200 - 3600 (Steps of 100 mm)	1192 - 3592 (Steps of 100 mm)	592	15	01, 02,
I-62	1200, 1800, 2400, 3000, 3600	1242, 1867, 2492, 3117, 3742	617		21, 22
X-60	1200 - 3600 (Steps of 100 mm)	1199 - 3599 (Steps of 100 mm)	599		03, 04, 05, 06, 07, 08, 14

Premium plus feature models


PREMUM	L* (mm)	A (mm)	B (mm)	kg / m	Ceiling type
Y-60	1200 - 3600 (Steps of 100 mm)	1174 - 3574 (Steps of 100 mm)	575	15	09, 11
Z-60	1200 - 3600 (Steps of 100 mm)	1184 - 3584 (Steps of 100 mm)	584		10

L\* = Nominal length ( Order length ).

# Installation instruction

# Premium/Pemax

### 3.3 Premium / Premax



### 3.4 Material data

Type	Premium	Pemax
Dry weight [kg/m]	15	18
Water content, cooling [l/m]	0.6	1.2
Water content, heating [l/m]	0.2	0.2
Copper pipes quality	EN 12735-2 CU-DHP	
Pressure class	PN10	

Material data.

### 3.5 Environmental Declarations

Please follow the links below:

- [Building product declaration](#)
- [Declaration of conformity](#)
- [Eurovent certificate](#)

### 3.6 Pressure Class

The waterborne products in Lindab, active chilled beams (battery products), passive chilled beams (battery and strips products), facade units (battery) and radiant panels (strips and panels) are produced according to pressure class PN 10 according to EN 1333: 2006.

This means the maximal working pressure for the products at a water temperature of 20°C must not exceed 10 bar.

### 3.7 Water quality

Lindab in general recommends the water treatment and quality to be according to:

**VDI 2035-2: 2009** “Prevention of damage in water heating installations Water-side corrosion”.

and

**VDI/WTGA 6044: 2023** “Prevention of damage in cold and cooling water circuits”.

- Water systems must be designed as corrosion sealed installations. However, the planning data must be documented in a system logbook (e. g. according to **VDI 2035 part 2**, Annex C).
- The water preparation and maintenance for the water system must be handled by a specialist.
- To prevent corrosion, the water system must be airtight, and a constant input of oxygen must be avoided. In addition, scheduled maintenance and, when necessary, repairs are important corrosion protective measures (all to be documented in the system logbook).
- Before commissioning, the water system installations must be flushed thoroughly (it has proven to be necessary to consider the flushing of the system in the planning process already) with filling or make up water (see **EN 14336**) to remove particulate foreign matter from circulating water (e. g. corrosion products, dirt, microorganism, welding/soldering residues, substances entered during tool damage or others). Detailed information on this is formulated in **WTGA Rule 3.002**.

# Installation instruction

# Premium/Premax

- The water system must be filled (and re-filled) with clean drinking water that complies with the “**EC directive 98/83/EC**”.

Appropriate measures must be undertaken and reported (system logbook) to ensure that the guide values are kept according to:

**VDI 2035 Part 2: 2009, for heating water systems**

Parameter	Unit	Low-saline	Saline
Electrical conductivity at 25 °C	µS/cm	< 100	100 - 1500
Appearance		Free of sedimentary substances	
pH-value at 25 °C		8.2 - 10.0	
Oxygen	mg/l	< 0.1	< 0.02

Guide values for the heating water.

and

**VDI/BTGA 6044 Part 4: 2023, for cooling water systems.**

Parameter	Unit	Value
Electrical conductivity	µS/cm	10.....1500
Appearance		Clear, free of sedimentary substances
pH-value		8.2 - 10.0
Total hardness	mol/m³	< 1.5
Iron	g/m³	< 0.5
Copper, zinc, aluminium	g/m³	< 0.2
TOC of the untreated water	g/m³	< 25
Oxygen	mg/l	< 0.1

Reference value table for filling, make-up and circulating cooling water.

- The water in the system must be always oxygen free, meaning an oxygen content of 0.1 mg/l in all parts of a water system must not be exceeded (**VDI 6044**) to prevent corrosion.
- The pH value of water must be between approximately 8.2 and 10.0 at 25 °C.
- The water velocities in the water system should not exceed 1 m/s to avoid corrosion and should be kept as close to the nominal flow as possible to minimize noise and optimize the energy yield.
- Lindab recommends to use in-line strainers, and filters (e. g. according to table 3 **VDI/BTGA 6044 Part 4: 2023**) in sensitive parts of the water system to remove dirt particles from the water. This can especially be fundamentally recommended in renovation of existing water systems.

- It can be further recommended (**VDI/BTGA 6044 Part 4: 2023**) to install a sensor-supported continuous monitoring of the circulation water and/or system for water treatment or purification in the bypass flow.
- If the water contains any additive inhibitor, then it must be appropriate to use with copper and solder and all other materials involved. If in doubt, do not hesitate to contact Lindab for further advice.

**Lindab reserves the right not to accept any claims related to leakage or corrosion in our products, if the system water quality of the filling water and the changed conditions during the entire period of operation have not been recorded in a system logbook or similar document, and/or one of the above recommendations has not been followed correctly.**

## 3.8 Air quality

Primary supply air have to be clean, dry and filtered before reaching the beam.

## 3.9 Capacity test

Lindabs active chilled beams are Eurovent-certified and tested according to EN-15116.



Please visit [Premium](#) or [Premax](#) on [www.lindQST.com](http://www.lindQST.com) and see [Eurovent](#) for more details.

# Installation instruction

# Premium/Premax

## 4. Connections

### 4.1. Water connections

Flow indication arrows are shown on the inlet and return pipes in order to assist the installer.

If the control valves have been ordered separately, a special direction of the flow must be upheld to ensure correct flow through the control valve. Please note the flow direction indicator on the valve to insure correct installation in relation to the desired flow.


When connecting a panel or a beam with the piping system either a push-on fitting or a compression coupling should be used. Lindab have tested and recommends John Guest push on fittings as well as push-on fittings from Tectite (available as accessory. See [Accessories](#)).

To avoid sound being transported over the beam, we recommend to use our flexible hoses between the piping and the beam connections. See [Accessories](#).




**NB!** Every control valve can create sound when it is installed directly connected to the water in- or outlet (or into the piping in close distance to the in- or outlet of the water product). To avoid unwanted sound generation we recommend to always use a Lindab control valve [LinFlow-A](#) (angled) or [LinFlow-S](#) (straight) and calculate the beam with the valve in [LindQST\waterborne calculator](#).

#### 4.1.1 Before installation

- Notice! The connection pipes are internally soft-welded, therefore it is not allowed to solder the beam to the pipes. For other than Lindab fittings and valves, please consult the installation guide for the specific fitting for further details on proper installation.
- Both inlet- and return pipes are covered by a plastic or rubber protection cover, which must be removed before installation.



- After removing the protection cover, make sure that the pipe is intact and undamaged, especially at the pipe end, as even small dents and scratches potentially pose a risk of leakage in the system.
- Eventually deburr the pipe ends on the inside and the outside, using a deburring tool before installation.




- Always remember to do a pressure test after assembly the pipe work.

# Installation instruction

# Premium/Premax

## 4.1.2 Push-on valve

- Mount a push-on valve to the pipe. Make sure the valve has the correct flow direction (see indication arrow on the valve) and that you have the correct valve, when integrated valve has been chosen (see indication on valve or follow cabelling to Regula Connect card). Cooper inserts aren't required!
- Please refer to the suppliers manual.






## 4.1.3 Compression fitting

- While mounting a compression fitting, the pipe will be exposed to a big amount of force, creating a risk of crushing the pipe. To ensure that the pipe won't be crushed when mounting the compression fitting, a copper insert must be inserted into the pipe (always part of the delivery).
- The copper insert should be placed inside the pipe on the beam. Always support the copper pipe coil when inserting the copper insert into position.
- Mount a compression coupling and/or a valve to the pipe. Don't stress the nut too much, since this may crush the pipe.
- Please refer to the suppliers manual.

## 4.1.4 Flexible hoses

- Our flexible hoses with straight ends can be used with both push-on and compression fitting.
- We recommend to use our flexible hoses with push-on fittings, for easier and faster mounting.
- For the connection to an enclosed valve with integrated push on coupling a flexible hose with straight end (male) or with push on (female) and a short copper pipe can be used.
- Please refer to the suppliers manual.



\*  $L_{min}$  = 70 mm (to ensure you can open the couplings again).

Lindab flexible hoses are available with straight end (male) for direct connection to Lindab valves also.

# Installation instruction


# Premium/Premax

## 4.1.5 Possible connections water cooling (2-pipe, standard)

All the Premium/Premax active chilled beams are in the standard version equipped with a so called “2-pipe connection” and contain one water circuit (cooling).

The dimension for all water pipe connections are 12 mm. Besides, the Premax can also be configured with 15 mm pipe connections.

**Premium/Premax I-60, I-62, X-60 cooling (standard), Y-60, Z-60 (plus features).**





# Installation instruction Premium/Premax

## 4.1.6 Possible connections water cooling and heating (4-pipe, plus feature)

All Premium/Premax' can have a 4-pipe water connection (plus feature), beside the cooling circuit also includes a heating circuit.

The dimension for all water pipe connections are 12 mm. Besides, the Premax can also be configured with 15 mm pipe connections (cooling only!).

### Premium/Premax I-60, I-62, X-60, Y-60, Z-60 cooling and heating (plus feature).



# Installation instruction


# Premium/Premax

## 4.2 Air connections

### 4.2.1 Air connection installation

The primary air supply must be connected with instructions from a ventilation specialist. Lindab's chilled beams can beneficially be used together with Lindab's Safe® duct systems.

We recommend a flexible duct connection, like Lindab DRATMFU-125, to balance out different installation heights or directions between connection and duct and avoid sound will be diverted from piping system to the ceiling.




### 4.2.2 Possible connections supply air (A, B, C, D)

Connection A is delivered with Lindab's standard nipple NPU-125.  
For connection B, C and D Lindab's elbow piece BU 90° is included.

### 4.2.3 Possible connections extract air (plus feature) (E, F, G, H)


Extract air connections must be placed at opposite end of chosen supply air connection. All 4 extract combinations are possible, BUT NOTE THAT extract air outlets can not be placed at the same point as the water inlet/outlets. The extract air plus feature includes a KSU-125 valve and a VGU-125 or a BU90°-125 piece as standard.



## 4.3 Possible combinations of connections (standard)

Possible Premium /Premax connections,  
Supply air (A, B, C, D) and water (1, 2, 3, 4, 7, 8).

<b>A:</b>	1, 2, 3, 4, 7, 8
<b>B:</b>	1, 2, 3, 4, 7, 8
<b>C:</b>	3, 4, 7, 8
<b>D:</b>	3, 4, 7, 8




# Installation instruction

# Premium/Premax

## 4.4 Electrical connections

Electrical connections on the beam are only necessary, when plus features are chosen and thanks to the pre-fabrication it is as easy as "plug and play". The components are always installed near the water-connection at the end of the beam. For further information, see [Regula](#).

### 4.4.1 Regula components on the beam




(with protection covers, optional).

# Installation instruction


# Premium/Premax

## 4.4.2 Example 1: Wiring scheme with Regula Connect multi

Please visit [www.lindQST.com](http://www.lindQST.com) and check out the “[Wiring scheme configurator](#)” for your set-up.



## 4.4.3 Example 2: Wiring scheme with Regula Connect basic



# Installation instruction

# Premium/Premax

## 4.4.4 Regula Connect on the beam

Connect cards are pre-installed when the beam is ordered with PLUS-features. See [Regula Connect](#) for more details.

### Regula Connect Basic



### Regula Connect Pascal




### Regula Connect Multi



## 4.4.5 Regula Secura on the beam

Regula Secura is pre-installed when the beam is ordered with PLUS-features. See [Regula Secura](#) for more details.

Condensation sensor and Regula Secura



## 4.4.6 Valves and Actuators on the beam

Description, see 2.16.3 and 2.16.4

## 4.4.7 Regula Combi on/with the beam

The Regula Combi can be controlled and programmed locally in the display, or at a remote location by a EXOLINE or MODBUS communication system. Handles both 24V and 0-10V devices.



See the [Regula Combi](#) documentation.

## 4.4.8 Actuators

Description, see 2.16.4.

# Installation instruction

# Premium/Premax

## 5. Installation of product

### 5.1 Handling of product

For the handling of the product please refer to 2.5.

### 5.2 Adaption to ceiling systems

#### 5.2.1 Ceiling systems


<b>01</b> T24/T15 Lay-in 600 Danotile T24/T25 Ecophon T24 Rockfon A24  595x595 Frame follows the box	<b>02</b> T24/T15 Lay-in 600 (I-60 ) Water not cleanable  595x595	<b>03</b> Permanent ceiling  (X) Water
<b>04</b> Dampa Clip-in bevelled edge  600x600 16 chamfer 45° x5	<b>05</b> Dampa Clip-in square edge  600x600 13	<b>06</b> Luxalon SQ Clip-in  (X) Water  600x600 26 chamfer 45°x3
<b>07</b> Danotile Contur Ecophon D Rockfon D-XL  599x599  11	<b>08</b> Ecophon Focus DG  592x592  8 15	<b>09</b> Rockfon E10 24 Ecophon -E /T24  (Y) Water  ( Plus feature )  575x575  10
<b>10</b> Rockfon E10 15 Ecophon -E / T15  ( Z ) Water  ( Plus feature )  584x584  10	<b>11</b> Danotile Markant  575x575   13	<b>14</b> Ecophon Focus DS Rockfon Sonar X  (X) Water  599x599   15
<b>21</b> T24/T15 Lay-in 625  <b>22</b> T24/T15 Lay-in 625 not cleanable  619x619	<b>31</b> T24/T15 Lay-in 675  <b>32</b> T24/T15 Lay-in 675 not cleanable  669x669	<b>31</b> T24/T15 Lay-in 675  (I-67 ) Water
		<b>32</b> T24/T15 Lay-in 675  (I-67 ) Water

# Installation instruction

# Premium/Premax

## 5.3 General installation principles


### 5.3.1 Recessed in suspended T-bar ceiling




### 5.3.2 Exposed, sealed to the ceiling




### 5.3.3 Exposed, free hanging




### 5.3.4 Free hanging above perforated or egg-crate ceiling



### 5.3.5 Recessed in suspended (permanent) ceiling



### 5.3.6 Recessed in suspended (permanent) ceiling without cover flanges.




# Installation instruction Premium/Premax

## 5.4 Preparation for installation on the product

The beam is prepared for installation by hangers (4 x per beam).

- Threaded rods M8
- Pendulum hangers (in different sizes)



PREMAX	L* (mm)	A (mm)	B (mm)	X (mm)
I-60	1200, 1800, 2400, 3000, 3600	1192, 1792, 2392, 2992, 3592	592	L - 325 ( 875, 1475, 2075, 2675, 2675, 3275 )
I-62	1200, 1800, 2400, 3000, 3600	1242, 1867, 2492, 3117, 3742	617	
X-60	1200, 1800, 2400, 3000, 3600	1199, 1799, 2399, 2999, 3599	599	

### Premax plus feature models

PREMAX	L* (mm)	A (mm)	B (mm)	X
Y-60	1200, 1800, 2400, 3000, 3600	1174, 1774, 2374, 2974, 3574	575	
Z-60	1200, 1800, 2400, 3000, 3600	1184, 1784, 2384, 2984, 3584	584	L - 325

PREMIUM	L* (mm)	A (mm)	B (mm)	X
I-60	1200 - 3600 (Steps of 100 mm)	1192 - 3592 (Steps of 100 mm)	592	L - 325
I-62	1200, 1800, 2400, 3000, 3600	1242, 1867, 2492, 3117, 3742	617	
X-60	1200 - 3600 (Steps of 100 mm)	1199 - 3599 (Steps of 100 mm)	599	





### Premium plus feature models

PREMIUM	L* (mm)	A (mm)	B (mm)	X
Y-60	1200 - 3600 (Steps of 100 mm)	1174 - 3574 (Steps of 100 mm)	575	L - 325
Z-60	1200 - 3600 (Steps of 100 mm)	1184 - 3584 (Steps of 100 mm)	584	

L\* = Nominal length ( Order length ).

# Installation instruction


## Premium/Premax



# Installation instruction

## Premium/Premax

### 5.5. Basics steps of installing the product



Note that this installation procedure shows installation in an existing T-bar ceiling. In a completely new building the beams will often be installed before the ceiling system.

# Installation instruction

# Premium/Premax


## 6. Adjustment and commissioning

### 6.1 Airflow and pressure

The JetCone System enables an easy and fast adjustment in both pressure and air volume (primary airflow rate) through the front side.



#### 6.1.1 Jetcone adjustment pins

Premium seen from below with faceplate open, showing location of the 2 Nozzles with JetCone units and the 4 adjustment pins.



## Installation instruction

## Premium/Premax



*Example of different air patterns that can be obtained using different pin positions.*

# Installation instruction


# Premium/Premax

## 6.1.2 Finding values for JetCone pins



Example 1: (Valid for Premium/Premax 1.2 m  $\leq$  L  $\leq$  2.0 m)

Premax-I-60-12-125-A1-1800-80-20

$\Delta p_{stat}$  = 80 Pa (Static pressure)  
 $q_a$  = 20 l/s (Primary airflow rate)



## 6.1.3 Adjusting air flow and pressure with JetCone pins.



# Installation instruction


# Premium/Premax

## Finding values for JetCone pins

Example 2: (Valid for Premium/Premax 2.0 m < L  $\leq$  3.6 m)


Premax-I-60-12-125-A1-2400-80-25

$$\begin{aligned}\Delta p_{\text{stat}} &= 80 \text{ Pa} & (\text{Static pressure}) \\ q_a &= 25 \text{ (l/s)} & (\text{Primary airflow rate})\end{aligned}$$




## Adjusting air flow and pressure with JetCone pins

### Symmetric adjustment



### Asymmetric adjustment




# Installation instruction

# Premium/Premax

## 6.2 Adjustment of air distribution profile (plus feature)

Premium/Premax<sup>®</sup> come as standard with fixed angled JetCone Nozzles. As a plus feature the inlet faceplate comes with the Lindab Airguide system pre-installed and pre-adjusted from factory, offering a readjustable air spread pattern control.


The Faceplate include 4 separate adjustable deflectors.



# Installation instruction

# Premium/Premax

Reposition adjustment "clips." (Lindab Airguide system).




## 6.3 Measuring air pressure and calculating the air flow

Before calculating the airflow, the static nozzle pressure must first be measured. The static nozzle pressure is the air pressure available at the nozzles.

### 6.3.1 Measuring static nozzle pressure and air pressure

- To measure the air pressure, a manometer, (analogue or digital) will be needed. Lindab recommends PC410.
- Insert the measuring tube onto the specialized measuring nozzle.
- Read of the static nozzle pressure from the manometer (PC410).



# Installation instruction Premium/Premax

## 6.3.2 Calculating the actual air flow

- After measuring the static pressure, read the settings of the four JetCone adjustment pins to find the mean value of the pins.
- Locate the diagram inside the openable perforated faceplate, (also see diagrams in 6.3.5), and use the static nozzle pressure and the mean value of the pins to find the current airflow.



## 6.3.3 Changing the actual air flow

- Measure the static nozzle pressure.
- Locate the air pressure/airflow diagram inside the openable perforated faceplate. (Also see diagrams in 6.3.5).
- Find the mean value of the 4 pins to reach the desired airflow, in the diagram. Use the static nozzle pressure and the desired airflow to find the mean value of the 4 pins.
- Adjust the 4 pins in the beam, so the mean value of the pins will correspond with the mean value found in the diagram.
- See example in 6.1.2 / 6.1.3.

## 6.3.4 Changing the air distribution profile

See 6.2.

## 6.3.5 Premium / Premax pressure / airflow diagrams



# Installation instruction Premium/Premax

## 6.4 Water flow rate

### 6.4.1 Pre-setting of valves

All the integrated control valves (plus feature) are delivered not set. The presetting has to be done on site. For the presetting of valves, please see [LinFlow-A](#) (Angled) and LinFlow-S (Straight) water valves documentation.

### 6.4.2 Balancing strategy

Lindab recommends always balancing the water system to guarantee thermal comfort in all areas, to avoid noise nuisance problems and to save energy. A hydraulic balance is obvious to ensure that all the beams (panels or facade units) in the system will always be supplied with their required (planned) water flow rates (calculated with [LindQST\waterborne calculator](#)).

Lindab refers to the proportional method, where all beams (panels or facade units) are balanced to the same proportion of the requested water flow rate.

# Installation instruction

# Premium/Premax

## 7. Maintenance


The interval of cleaning depends on the indoor environment where the beam is placed. Under optimal conditions the beams only need cleaning every 5 years.

- Open the inlet plate using no tools (7.2).
- Clean the battery downside and the inlet faceplate inner parts with a dust cleaner / vacuum cleaner.
- Only use lukewarm water and a mild detergent and a piece of wet cloth to clean the inlet face plate.
- Open the inspection hatch (7.3).
- Clean the air plenum chamber and air connection with a vacuum cleaner.
- Clean the top side of the battery, nozzle plate, JetCones and the mixing chamber with a dust cleaner / vacuum cleaner.

### 7.1 Remove the outlet front grille

Not relevant for Premium/Premax.

### 7.2 Open inlet faceplate



### 7.3 Open inspection hatch

Take out end-cap with *Lindab safe* to get acces to air duct for cleaning.

Note that this air duct end-cap can be situated different places on the beam depending on which model and which plus features are chosen.

### 7.4 Lower battery

Not relevant for Premium/Premax.

# Installation instruction

# Premium/Premax

## 8. Accessories

Ask Lindab for the accessories mentioned in this document. Additional accessories (or additional dimensions) are available on request.\*\*

Order code	Order number
2-way Control valve LinFlow-S-12 straight - push on	686552
2-way Control valve LinFlow-S-15 straight - push on	686553
2-way Control valve LinFlow-A-12 angled - push on	686554
Actuator A 40405 24 V on/off NC - 1 m, non-halogen cable	684601
Actuator A 41405 24 V on/off NO - 1 m, non-halogen cable	684603
Actuator APR 40405 0-10 V mod. NC, 1 m, non-halogen cable	684667
Actuator APR 40405 0-10 V mod. NC, 1 m, cable	684604
Ballofix Broen 12 mm with handle - shut-off valve	642663
Ballofix Broen 12 mm without handle - shut-off valve	642662
Ballofix Broen 15 mm with handle - shut off valve	642122
Ballofix Broen 15 mm without handle - shut off valve	642121
Copper insert 12 x 1,0 mm	884022
Copper insert 15 x 1,0 mm	653455
Flexible hose O2stopp_DN10 0,4 m - JG12 push - JG12 push	686566
Flexible hose O2stopp_DN10 0,4 m - JG12 push - straight end 12 mm	175984
Flexible hose O2stopp_DN10 0,4 m - JG15 push - JG15 push	686568
Flexible hose O2stopp_DN13 0,4 m - JG15 push - JG15 push	175808
Lindab PC 410	103344
Pendulum 180-300 mm	642480
Pendulum 540-1000 mm	646742
Regula Combi see: "Accessories"	**
Regula Connect Card Basic	*/**
Regula Connect Card Multi	*/**
Regula Secura	**
Aerator 12 mm - tectite	647690
Aerator 15 mm - tectite	647691
Tectite angle 12 mm	884014
Tectite angle 15 mm	642596
Tectite straight 12 mm	884050
Tectite straight 15 mm	642597
Tectite demounting tool 12 mm	884087
Tectite demounting tool 12 mm, small	646881
Tectite demounting tool 15 mm, small	646882
Touch-up paint RAL 9010 - 25 ml	642531
Touch-up paint RAL 9003 - 25 ml	174759
Transformer 24V AC output	*/**

\*see: "Regula Connect – What do I get?"

\*\*see: "Accessories"



Most of us spend the majority of our time indoors. Indoor climate is crucial to how we feel, how productive we are and if we stay healthy.

We at Lindab have therefore made it our most important objective to contribute to an indoor climate that improves people's lives. We do this by developing energy-efficient ventilation solutions and durable building products. We also aim to contribute to a better climate for our planet by working in a way that is sustainable for both people and the environment.

[Lindab | For a better climate](#)